
POLYCAB

CABLES





LT XLPE CABLE

TDS Doc.No:PIL/TE/250425/001036

DESIGN CODE : LVIS09CXUAY2003C150SA001S

Particulars		3 Core X 150 Sq.mm
Name of Manufacturer		Polycab India Ltd
Type of cable		2XY
Voltage Grade V		1100
No of cores X size in sqmm		3 Core X 150 Sq.mm
Conductor		
a)	Material	Plain annealed Copper as per Class 2 of IS:8130/2013, latest
b)	Max. d.c. resistance of conductor at 20° C (ohm/km)	0.124
c)	Shape of the conductor	Stranded Compacted Sector
Insulation		
a)	Material	XLPE as per IS 7098(Pt-1)/88, Latest
b)	Nominal thickness (mm)	1.4
c)	Core identification	Red,Yellow,Blue
Inner Sheath		
a)	Material	Extruded PVC Type ST2 as per IS:5831/84
b)	Minimum thickness (mm)	0.5
Outer Sheath		
a)	Material	Extruded PVC Type 'ST2' as per IS:5831 / 84
b)	Thickness (mm)	2.4 (Nom.)
c)	Colour of sheath	Black
Electrical Parameters		
a)	Max. a.c. resistance of conductor at 90° C (ohm/km)	0.160
b)	Calculated Cable reactance (ohm/km)	0.0718
c)	Impedance of cable (ohm/km)	0.175
Maximum conductor temperature under normal operating conditions		90°C
Maximum conductor temperature at the termination of short circuit		250°C

Format ID: TE/QMS/F/07, R-00, Date: 16/03/2025

Short Circuit rating of conductor for the duration of 1 sec (kA)	21.46
Continuous Current carrying capacities :-	
(a) In Ground at 30°C (A)	321
(b) In Air at 40°C (A)	365
Applicable Standard	IS 7098 Part I/88,IS 8130/2013,IS 5831/84 etc. with latest up to date amendments
Approx. overall diameter of the cable in mm	38.0 ± 2.0
Minimum bending radius	12 times Overall diameter
Max. Tensile strength	
(i) for Cables pulled with stocking (Newtons)	5 x D^2, D is the cable OD in mm
ii) for Cables pulled with pulling eyes (N)	22500
Embossing	POLYCAB ELECTRIC 1100 VOLTS GRADE XLPE
Printing	YEAR POLYCAB ELECTRIC 1100 VOLTS GRADE XLPE CABLE SIZE CABLE TYPE WITH SEQUENTIAL MARKING at every one meter interval.
Standard Drum Length (Mtr.)	500 ± 5%
Non- Standard Drum Length (Mtr.)	Maximum 5% of order quantity

Note:-The values given above are subject to tolerances as per the relevant standards